

Certificates




Maintaining electrical functionality

Mesh cable tray GR-Magic® - Center suspension

General building authority test certificate no. P-MPA-E-18-004, valid until 22.08.2023

This is a translation of the original German version, which has neither been checked nor approved by the NRW Materials Testing Office. Only the original German document is valid.





Be it in a residential building or an industrial complex – OBO has the appropriate solution for fireproof electrical installations. Our tested and certified fire protection systems cover all the relevant fire protection guidelines and provide you with an electrical installation that really serves its purpose. We will be happy to provide you with more details – on our website or personally.

This is a translation of the original German version, which has neither been checked nor approved by the NRW Materials Testing Office. Only the original German document is valid.

Erwitte Branch Office • Auf den Thränen 2 • 59597 Erwitte • Tel +49 (0)2943 897-0 • Fax +49 (0)2943 897-33 • E-mail: erwitte@mpanrw.de

General building authority test certificate

Test certificate number: P-MPA-E-18-004

Subject: Cable system with integrated maintenance of electrical function

in the function maintenance classes E30 to E90 as described in DIN 4102-12: 1998-11 pursuant to Building Rules List A Part 3,

No. 2.9 (Edition 2015-2)

Applicant: OBO Bettermann Produktion Deutschland GmbH & Co. KG

Hüingser Ring 52

58710 Menden, Germany

Date of issue: 23.08.2018

Valid until: 22.08.2023

The aforementioned product can be used in compliance with the state building regulations based on this general building authority test certificate.

This general building authority test certificate comprises 9 pages and 12 annexes.

1 Subject matter and scope of application

1.1 Subject

1.1.1

This general building authority test certificate applies to the manufacture and use of the cable system with integrated maintenance of electrical function as a construction type. The cable system with integrated maintenance of electrical function allows classification into function maintenance classes E 30 to E 90 (depending on the cable construction type) as described in DIN 4102-12 (edition 11/1998).

1.1.2

The cable system with integrated maintenance of electrical function must consist of the cable construction types described in Section 3.1 and a cable support structure as described in Section 3.2.

Table 1

Installation type

1 Ceiling mounting

Mesh cable tray GRM55 200 with centre suspension GMS 170 (a \leq 1,000 mm) (b = 200 mm) (g \leq 7.5 kg/m)

2 Ceiling mounting

Mesh cable tray GRM55 200 with centre suspension GMS 170 (a \leq 1,250 mm) (b = 200 mm) (g \leq 7.5 kg/m)

Cable construction type:	Installation type	Dimension:	Classification:
Manufacturer's designation EUPEN EUCASAFE	no.:	wire count x cross-section [n x mm²] or wire count x 2 x diameter [n x 2 mm]	pursuant to DIN 4102-12 1998-11
(N)HXH FE180 E30 VDE 0266	1	n x 1.5–25	E30
VDE 0200 VDE reg. no. 8512 and 7581	1	n x 1.5–25	E60
(N)HXCH FE180 E30 VDE 0266 VDE reg. no. 8512 and 7581	2	n x 1.5/1.5–25/16	E30
	1	n x 1.5–25	E30
(N)HXH FE180 E90 VDE 0266	1	n x 1.5–25	E60
VDE reg. no. 8566 and 8513	2	n x 25	E60
	1	n x 1.5	E90
	1	n x 1.5/1.5–25/16	E30
(N)HXCH FE180 E90 VDE 0266	1	n x 1.5/1.5–25/16	E60
VDE 0266 VDE reg. no. 8566 and 8513	1	n x 1.5/1.5–25/16	E90
	2	n x 25/16	E90
JE-H(St)H FE180 E30 VDE reg. no. 7510	2	n x 2 x 0.8	E30

Table 1 (continued)

Installation type

1 Ceiling mounting

Mesh cable tray GRM55 200 with centre suspension GMS 170 (a \leq 1,000 mm) (b = 200 mm) (g \leq 7.5 kg/m)

2 Ceiling mounting

Mesh cable tray GRM55 200 with centre suspension GMS 170 (a \leq 1,250 mm) (b = 200 mm) (g \leq 7.5 kg/m)

Cable construction type: Manufacturer's designation Dätwyler Pyrofil Keram	Installation type no.:	Dimension: wire count x cross-section [n x mm²] or wire count x 2 x diameter [n x 2 mm]	Classification: pursuant to DIN 4102-12 1998-11
(N)HXH FE180 E30-E60 VDE reg. no. 7780	2	n x 1.5–25	E30
(N)HXCH FE180 E30-E60	1	n x 6/6–25/16	E30
VDE reg. no. 7780	1	n x 6/6	E60
	1	n x 1.5–25	E30
(N)HXH FE180 E90 VDE reg. no. 7780	1	n x 1.5–25	E60
	1	n x 1.5	E90
	1	n x 1.5/1.5–25/16	E30
(N)HXCH FE180 E90 VDE reg. no. 7780	1	n x 1.5/1.5–25/16	E60
	1	n x 1.5/1.5–25/16	E90
JE-H(St)HRH FE180 E30- E90 VDE reg. no. 9361	1	n x 2 x 0.8	E30

Table 1 (continued)

Installation type

1 Ceiling mounting

Mesh cable tray GRM55 200 with centre suspension GMS 170 (a \leq 1,000 mm) (b = 200 mm) (g \leq 7.5 kg/m)

2 Ceiling mounting

Mesh cable tray GRM55 200 with centre suspension GMS 170 (a \leq 1,250 mm) (b = 200 mm) (g \leq 7.5 kg/m)

Cable construction type: Manufacturer's designation LEONI Studer BETAflam	Installation type no.:	Dimension: wire count x cross-section [n x mm²] or wire count x 2 x diameter [n x 2 mm]	Classification: pursuant to DIN 4102-12 1998-11
(N)HXH FE180 / E30-E60 S VDE reg. no. 8849	1	n x 1.5 - 16	E30
(N)HXH FE180 / E30-E60 VDE reg. no. 9803	1	n x 16 - 25	E30
(N)HXCH FE180 / E30-E60 VDE reg. no. 9803	1	n x 1.5/1.5–25/16	E30
(N)HXH FE180 / E90	1	n x 1.5–25	E30
VDE reg. no. 9803	1	n x 1.5	E60
(N)HXCH FE180 / E90	1	n x 1.5/1.5–25/16	E30
VDE reg. no. 9803	1	n x 25/16	E60
JE-H(St)H FE180 / E30 S VDE reg. no. 8619	1	n x 2 x 0.8	E30
JE-H(St)H FE180 / E30-E90 VDE reg. no. 9593	2	n x 2 x 0.8	E30
JE-H(St)HRH FE180 / E30- E90 VDE reg. no. 8238	2	n x 2 x 0.8	E30

2.1 Area of application

2.1.1

The area of application is limited to cables with nominal voltages of ≤ 1 kV. When dimensioning cable systems with integrated maintenance of electrical function, the possibility of the cables becoming functionally impaired due to thermally induced resistance increases must be considered.

2.1.2

A combination of different laying methods is permissible, provided they have the same maintenance of electrical function classes.

2.1.3

If there are additional requirements, these must be demonstrated separately.

3 Provisions for execution

The cable system must be designed in accordance with the following details.

3.1 Cable construction types

Only the cable construction types listed in Table 1, and with valid VDE approvals, may be used. The structural design of the cable construction types is on file at MPA NRW.

3.2 Cable support structures

The cable support structure must be made of steel (S235, see details in Table 1 and the appendix). The cable support structure and clips may be coated with plastics or fire protection paint up to a thickness of 1.5 mm.

3.2.1

Colour coatings and paints with commercially available thicknesses of up to 150 μm are permissible.

The following points should be observed:

Components under tensile stress should be dimensioned in such a way that their calculated tensile stress is not greater than 9 N/mm² (classifications E30 and E60) or not greater than 6 N/mm² (classification E90) as defined in Table 109 of DIN 4102-4:1994-03.

Anchors must comply with the specifications of the applicable general building authority approvals issued by Deutsches Institut für Bautechnik (the German Institute of Construction Technology), Berlin, and must also be installed twice as deep as specified in the approval notice – and at least 6 cm deep – unless otherwise stated in the approval; the calculated tensile load per anchor shall not exceed 500 N, cf. DIN 4102-4:1994-03, Section 8.5.7.5. Alternatively, anchors may be used whose suitability for fire protection is demonstrated by a general building authority approval, a European technical approval or assessment, or a

general building authority test certificate. They must be installed in accordance with the specifications of the general building authority approval or general building authority test certificate.

The general building authority test certificate only applies if:

- the cables or lines are designed without connecting elements;
- it is ensured that cable systems with integrated maintenance of electrical function are not negatively impacted in their function maintenance class by surrounding components.

3.3 Labelling

3.3.1 Cable construction types

The cable must be labelled in accordance with VDE regulations.

3.3.2 Cable system with integrated maintenance of electrical function

Each cable installation must be permanently marked with a plate or sticker attached to the cable support structure and displaying the following information:

- Name of the contractor who manufactured the cable system with integrated maintenance of electrical function;
- Cable system with integrated maintenance of electrical function E... pursuant to DIN 4102-12:1998-11;
- General building authority test certificate no. P-MPA-E-18-004 dated 23.08.2018, MPA Erwitte;
- Holder of the general building authority test certificate OBO Bettermann Produktion Deutschland GmbH & Co. KG, Hüingser Ring 52, 58710 Menden;
- Year of manufacture.

4 Proof of conformity

The construction type described in this general building authority test certificate requires proof of conformity (compliance certificate) as defined by the specifications of Building Rules List A Part 3 (no. C 2.9), according to which the manufacturer (contractor) must issue a declaration of conformity.

The contractor who manufactures the cable system must issue a written declaration of conformity to the client certifying that the cable system complies with the provisions of this general building authority test certificate.

5 Legal basis

This general building authority test certificate is issued on the basis of § 22 III of the building regulations of the state of North Rhine-Westphalia (BauO NW) dated 22.07.2003, in conjunction with Building Rules List A, Edition 2015/2. The state building codes of the other federal states contain equivalent legal bases.

6 Legal information

Objection may be raised to this notification, within one month of its publication, at the Gelsenkirchen Administrative Court, Bahnhofsvorplatz 3, 45879 Gelsenkirchen, Germany, in writing, or for the record of the clerk of that court's office. The objection must designate the plaintiff, the defendant and the subject of the claim and should entail a specific request. The facts and evidence serving as grounds must be stated and the original or a copy of the contested notification should be attached. Copies for the other parties involved should be attached to the objection.

7 General information

This general building authority test certificate proves the usability of the construction product/applicability of the construction type in compliance with the state building regulations.

The general building authority test certificate does not replace the permits, approvals and certificates required by law when carrying out building projects.

This general building authority test certificate is issued without prejudice to the rights of third parties, in particular private property rights.

Manufacturers and distributors of the construction product/type shall, without prejudice to further regulations in the "Special Provisions", provide the user of the construction product/type with copies of the general building authority test certificate and indicate that the general building authority test certificate must be available at the place of use. Copies of the general building authority test certificate shall be provided to the authorities involved on request.

The general building authority test certificate may only be duplicated in its entirety. Publication of extracts requires the consent of the testing centre. Text and drawings in promotional literature must not contradict the general building authority test certificate. Translations of the general building authority test certificate must include the note "This is a translation of the original German version and has not been checked by the NRW Materials Testing Office".

This general building authority test certificate is revocable. The provisions of the general building authority test certificate may be added to or amended later, especially if technical findings so dictate.

The test reports for this general building authority test certificate have been communicated to MPA NRW by the client.

Erwitte, 23.08.2018

On behalf of

Friedrichs
Deputy Director of the Testing Centre


Diekmann


Clerk


Sample for


Declaration of Compliance

*)	Delete where not applicable
•	ne certificate is to be given to the builder so that it can be passed on to the sponsible building inspection authorities.)
Pla	ace, date Stamp and signature
-	corresponding written confirmations from the manufacturers of the construction products or parts, which the signatory has kept on file. *)
-	internal checks; *)
-	the markings on the parts in compliance with the provisions of the general building authority test certificate; *)
	r construction products or individual parts not manufactured by the undersigned g. cable construction types), this is also hereby confirmed on the basis of:
ele pro bu	is hereby confirmed that the cable system(s) with integrated maintenance of ectrical function of class E has/have been manufactured and installed of of significate and in compliance with all the provisions of general ilding authority test certificate No. P-MPA-E-12-011 issued by MPA NRW on .07.2017.
-	Maintenance of electrical function class required by the cable system(s) with integrated maintenance of electrical function: E
-	Date of manufacture:
-	Construction site or building:
-	Name and address of the contractor who manufactured the cable system with integrated maintenance of electrical function;











38

ein- 1881






F	Formteilbogen 22,5°				
		22,5°	GRM 55 200		
Е	1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	GS	Mittenabhängun GMS 170	g -	
D	GSV 34	F			
С	Mittenabhängung GMS 170		F (1:2	2)	
		GRM 55	200		
В	Oberflaeche:			Eckverb GEV 36	
В	Oberflaeche: Werkstoff:	GRM 55	zulaessige Abweichung:	Eckverb GEV 36	
В	Part of the Art Offices		zulaessige Abweichung: Detailansicht Funktionserhalt	Eckverb GEV 36	
В	Werkstoff:		zulaessige Abweichung: Detailansicht Funktionserhalt Gitterrinne GRM 55 200	Eckverb GEV 36	
В	Werkstoff: Freigegeben Ind. Aenderung Artikel Datum Name	Farbe: OBO BETTERMANN GmbH&CO.KG DE Datum Name Ersteller 10.01.2018 S. Foobe	zulaessige Abweichung: Detailansicht Funktionserhalt Gitterrinne GRM 55 200	Eckverb GEV 36	icht:
В	Freigegeben Ind. Aenderung Artikel Datum Name	Farbe: OBO BETTERMANN GmbH&CO.KG DE Datum Name Ersteller 10.01.2018 S. Fobbe Bearb. 10.01.2018 S. Fobbe	zulaessige Abweichung: Detailansicht Funktionserhalt Gitterrinne GRM 55 200 zu: Mittenabhängung GMS	Eckverb GEV 36	icht:
B	Freigegeben Ind. Aenderung Artikel Datum Name	Farbe: OBO BETTERMANN GmbH&CO.KG DE Datum Name Ersteller 10.01.2018 S. Fobbe Bearb. 10.01.2018 S. Fobbe Geprueft 10.01.20 T. Fabry Maßstab	zulaessige Abweichung: Detailansicht Funktionserhalt Gitterrinne GRM 55 200 zu: Mittenabhängung GMS 1	Eckverb GEV 36	
В	Freigegeben Ind. Aenderung Artikel Datum Name-	Farbe: OBO BETTERMANN GmbH&CO.KG DE Datum Name Ersteller 10.01.2018 S. Fobbe Bearb. 10.01.2018 S. Fobbe Geprueft 10.01.20 T. Fabry	zulaessige Abweichung: Detailansicht Funktionserhalt Gitterrinne GRM 55 200 zu: Mittenabhängung GMS	Gew	icht:

rhandlungen verpflichlen zu Schadenersatz. Alle Rechte füer Petenterteilung oder Gebrauchsmuster - Eintragung vorbehall



Mesh cable tray type GRM 55 200





Dimension B: 200 mm


Diameter of longitudinal wire: 3.9 mm

Diameter of transverse wire: 3.9 mm



Centre suspension type GMS 170






Dimension B: 170 mm



Joint connector type GSV 43






Truss-head bolt: M6 x 20 with combination nut M6



Corner connector type GEV 36





Truss-head bolt:

M6 x 12 with combination nut M6

OBO Bettermann Holding GmbH & Co. KG

P.O. Box 1120 58694 Menden GERMANY

Customer Service

Tel.: +49 23 73 89-13 00 Fax: +49 23 73 89-71442

toi@obo.de

www.obo-bettermann.com

OBO Bettermann



BETTERMANN